

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE



LISTING No. 7300-1615: 222

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Bosch Security Systems, 130 Perinton Parkway, Fairport, NY 14450
Contact: Frank Mioduszewski (585) 678-3368 FAX (585) 678-3263

DESIGN: Models FCA-500 and FCA-500-E detector bases. The FAA-500-BB-UL back box is used as a recessed junction box for flush mounting these two bases. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 9.7 – 30 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as detector bases for use with listee's separately listed fire alarm control units and Models FCP-500 series (CSFM Listing No. *7272-1615:221) photoelectric smoke detectors. Refer to listee's Installation Instruction Manual for details.

*Corrected 07-13-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 29, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division